

# Energy performance certificate (EPC)


6 WELLINGTON PARADE LARNE BT40 1EG		Energy rating <b>E</b>
Valid until <b>18 April 2031</b>	Certificate number <b>0639-8624-5000-0481-5292</b>	

<b>Property type</b>	Mid-terrace house
<b>Total floor area</b>	104 square metres

## Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be D.

[See how to improve this property's energy performance.](#)



The graph shows this property's current and potential energy efficiency.

Properties are given a rating from A (most efficient) to G (least efficient).

Properties are also given a score. The higher the number the lower your fuel bills are likely to be.

The average energy rating and score for a property in Northern Ireland are D (60).

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, 75 mm loft insulation	Average

Feature	Description	Rating
Window	Fully double glazed	Average
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system, no cylinder thermostat	Poor
Lighting	Low energy lighting in 17% of fixed outlets	Poor
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	None	N/A

## Primary energy use

The primary energy use for this property per year is 272 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [What is primary energy use?](#)

### Environmental impact of this property

One of the biggest contributors to climate change is carbon dioxide (CO<sub>2</sub>). The energy used for heating, lighting and power in our homes produces over a quarter of the UK's CO<sub>2</sub> emissions.

**An average household produces**

6 tonnes of CO<sub>2</sub>

**This property produces**

7.3 tonnes of CO<sub>2</sub>

**This property's potential production**

4.5 tonnes of CO<sub>2</sub>

By making the [recommended changes](#), you could reduce this property's CO<sub>2</sub> emissions by 2.8 tonnes per year. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

**How to improve this property's energy performance**

Making any of the recommended changes will improve this property's energy efficiency.

If you make all of the recommended changes, this will improve the property's energy rating and score from E (48) to D (68).

► [What is an energy rating?](#)

Potential energy  
rating

**D**

**Recommendation 1: Increase loft insulation to 270 mm**

Increase loft insulation to 270 mm

**Typical installation cost**

£100 - £350

**Typical yearly saving**

£42

**Potential rating after carrying out recommendation 1**

50 | E

**Recommendation 2: Cavity wall insulation**

Cavity wall insulation

**Typical installation cost**

£500 - £1,500

**Typical yearly saving**

£129

**Potential rating after carrying out recommendations 1 and 2**

56 | D

**Recommendation 3: Hot water cylinder insulation**

Increase hot water cylinder insulation

**Typical installation cost**

£15 - £30

**Typical yearly saving**

£32

**Potential rating after carrying out recommendations 1 to 3**

58 | D

## Recommendation 4: Low energy lighting

Low energy lighting

**Typical installation cost** £50

**Typical yearly saving** £57

**Potential rating after carrying out recommendations 1 to 4**

59 | D

## Recommendation 5: Hot water cylinder thermostat

Hot water cylinder thermostat

**Typical installation cost** £200 - £400

**Typical yearly saving** £22

**Potential rating after carrying out recommendations 1 to 5**

60 | D

## Recommendation 6: Heating controls (room thermostat)

Heating controls (room thermostat)

**Typical installation cost** £350 - £450

**Typical yearly saving** £63

**Potential rating after carrying out recommendations 1 to 6**

63 | D

## Recommendation 7: Replace boiler with new condensing boiler

Condensing boiler

**Typical installation cost** £2,200 - £3,000

**Typical yearly saving** £126

## Potential rating after carrying out recommendations 1 to 7

68 | D

## Recommendation 8: Floor insulation (solid floor)

Floor insulation (solid floor)

**Typical installation cost**

£4,000 - £6,000

**Typical yearly saving**

£34

## Potential rating after carrying out recommendations 1 to 8

70 | C

## Recommendation 9: Solar water heating

Solar water heating

**Typical installation cost**

£4,000 - £6,000

**Typical yearly saving**

£44

## Potential rating after carrying out recommendations 1 to 9

72 | C

## Recommendation 10: Solar photovoltaic panels, 2.5 kWp

Solar photovoltaic panels

**Typical installation cost**

£3,500 - £5,500

**Typical yearly saving**

£337

## Potential rating after carrying out recommendations 1 to 10

81 | B

## Paying for energy improvements

[Find energy grants and ways to save energy in your home. \(https://www.gov.uk/improve-energy-efficiency\)](https://www.gov.uk/improve-energy-efficiency)

### Estimated energy use and potential savings

**Estimated yearly energy cost for this property**

£1203

**Potential saving**

£472

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

The estimated saving is based on making all of the recommendations in [how to improve this property's energy performance](#).

**Heating use in this property**

Heating a property usually makes up the majority of energy costs.

**Potential energy savings by installing insulation**

The assessor did not find any opportunities to save energy by installing insulation in this property.

**Contacting the assessor and accreditation scheme**

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

**Assessor contact details****Assessor's name**

Brian Todd

**Telephone**

028 28279477

**Email**[brian@briantodd.co.uk](mailto:brian@briantodd.co.uk)**Accreditation scheme contact details****Accreditation scheme**

Elmhurst Energy Systems Ltd

**Assessor ID**

EES/009606

**Telephone**

01455 883 250

**Email**[enquiries@elmhurstenergy.co.uk](mailto:enquiries@elmhurstenergy.co.uk)**Assessment details**

<b>Assessor's declaration</b>	Relative of the professional dealing with the property transaction
<b>Date of assessment</b>	19 April 2021
<b>Date of certificate</b>	19 April 2021
<b>Type of assessment</b>	▶ <a href="#">RdSAP</a>

**Other certificates for this property**

If you are aware of previous certificates for this property and they are not listed here, please contact us at [mhclg.digital-services@communities.gov.uk](mailto:mhclg.digital-services@communities.gov.uk), or call our helpdesk on 020 3829 0748.

There are no related certificates for this property.